

YORK SUBURBAN SCHOOL DISTRICT

Lead Testing In Schools

Jessica Thompson
November 16, 2024

Inspiring a BOLD Future





Act 39 of 2018

Lead Testing in Schools

- School districts in Pennsylvania MAY, but are not required to, test for lead levels in drinking water annually at any building where children attend.
- Drinking water shall be tested in accordance with the Lead Copper Rule set forth by the Pennsylvania Department of Environmental Protection.
- If lead is detected over action levels of **0.015 mg/L** a plan shall be implemented to ensure no student, staff member or visitor is exposed to contaminated drinking water.



Lab Testing & Monitoring

- Tests will be performed annually in the first marking period of each school year at water coolers (fountains) and sinks used to prepare food or wash hands.



Record Retention

- Analysis reports with corresponding chain of custody forms will be kept in the office of the Director of Facilities and are available for public viewing anytime.
- Yearly updates will be provided to the School Board of Directors and published on the York Suburban Website under the Facility Department.



Elementary Results

| <u>Date</u> | <u>Sample Location</u> | <u>Results</u> |
|-------------|-----------------------------------|----------------|
| 10/18/24 | East York Nurse's Office | 0.011 mg/L |
| 10/18/24 | Education Center Women's Restroom | <0.001 mg/L |
| 10/18/24 | Facility Building Restroom | <0.001 mg/L |
| 10/18/24 | Indian Rock Nurse's Office | <0.001 mg/L |
| 10/18/24 | Valley View Nurse's Office | <0.001 mg/L |
| 10/18/24 | Yorkshire Nurse's Office | 0.007 mg/L |



Secondary Results

| <u>Date</u> | <u>Sample Location</u> | <u>Results</u> |
|-------------|------------------------------|----------------|
| 10/18/24 | Middle School Nurse's Office | <0.001 mg/L |
| 10/18/24 | High School Nurse's Office | 0.001 mg/L |